# E3Z-LS

CSM\_E3Z-LS\_DS\_E\_3\_1

### Reliable Detection of Glossy, Uneven **Objects Regardless of Background or** Color.

- Switching between background and foreground suppression (BGS/ FGS) enables detecting a variety of objects under various background/foreground conditions.
- Unique algorithm minimizes external interference from inverter fluorescent lighting.
- Minimal differential travel to enable detecting small steps.
- Provides a high degree of protection (IP67), mutual interference prevention, and EN standard compliance.



CE



Be sure to read Safety Precautions on page 8.

### **Ordering Information**

### Sensors (Refer to Dimensions on page 10.)

Red light

Sensing method	Appearance	Connection method	Sensing distance (white paper)	Mod NPN output	del PNP output
Distance- settable		Pre-wired (2 m) *1	20 mm 40 mm 200 mm  BGS (at min. setting) Incident light level threshold (fixed)	E3Z-LS61 2M *2	E3Z-LS81 2M
		Connector (M8, 4 pins)	FGS (at min. setting) FGS (at max. setting)	E3Z-LS66	E3Z-LS86
		Pre-wired (2 m) *1	2 mm 20 mm 80 mm BGS (at min. setting)	E3Z-LS63 2M	E3Z-LS83 2M
		Connector (M8, 4 pins)	BGS (at max. setting)	E3Z-LS68	E3Z-LS88

<sup>1.</sup> Models with a 0.5-m cable are available. When ordering, specify the cable length by adding the code "0.5M" to the model number (e.g., E3Z-LS61 0.5M). \*2. The following table shows the model numbers of e-CON Pre-wired Connectors that are available. The Ratings and Specifications are the same as those for the E3Z-LS61.

Cable length	Model
0.3 m	E3Z-LS61-ECON 0.3M
0.5 m	E3Z-LS61-ECON 0.5M
2 m	E3Z-LS61-ECON 2M

### **Accessories (Order Separately)**

**Mounting Brackets** 

### Sensor I/O Connectors (Refer to Dimensions on XS3)

Cable specification	Appearance		Type of cable		Model
	Straight		2 m	4-wire	XS3F-M421-402-A
Otan dand MO askla			5 m		XS3F-M421-405-A
Standard M8 cable	L-shaped		2 m		XS3F-M422-402-A
			5 m		XS3F-M422-405-A

OMRON

### **Ratings and Specifications**


Sensing method		Distance-settable Distance-settable						
Model NPN output		E3Z-LS61 E3Z-LS66 E3Z-LS63 E3Z-LS6						
Item	PNP output	E3Z-LS81	E3Z-LS86	E3Z-LS83	E3Z-LS88			
	BGS	White or black paper (100 × 100 mm): 20 mm to set distance 2 mm to set distance (80 mm max.)						
Sensing distance	FGS	min.	n): Set distance to 200 mm n): Set distance to 160 mm					
Setting rang	je	White paper (100 $\times$ 100 mr Black paper (100 $\times$ 100 mr		White paper (100 × 100 mm): 20 to 80 mm				
Differential travel		10% of set distance max. ( vs. Sensing Distance on page 2)		2% of set distance max.				
Reflectivity (black/white	characteristic error)	10% of set distance max.		5% of set distance max.				
Light source	e (wavelength)	Red LED (680 nm) Red LED (650 nm)						
Power supp	ly voltage	12 to 24 VDC ±10%, ripple	(p-p): 10% max.					
Current con	sumption	30 mA max.						
Control outp	out	Load power supply voltage: 26.4 VDC max., Load current: 100 mA max. (residual voltage 1 V max.), Open collector output (NPN or PNP depending on model) Light-ON/Dark-ON switch selectable						
BGS/FGS se	election	BGS: Open or connected to FGS: Connected to Vcc	o GND	BGS: Open or connected to GND				
Protection c	ircuits	Reversed power supply po	larity protection, Output shor	t-circuit protection, Mutual i	nterference prevention			
Response ti	me	Operate or reset: 1 ms max.						
Distance set	tting	5-turn endless adjuster						
Ambient illumination (Receiver side)		Incandescent lamp: 3,000 lx max.; Sunlight: 10,000 lx max.						
	nperature range	Operating: -25 to 55°C, Storage: -40 to 70°C (with no icing or condensation)						
Ambient hur	midity range	Operating: 35% to 85%, Storage: 35% to 95% (with no condensation)						
Insulation re	esistance	20 MΩ min. at 500 VDC						
Dielectric st	rength	1,000 VAC at 50/60 Hz for 1 minute						
Vibration res	sistance	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions						
Shock resist	tance	Destruction: 500 m/s² for 3 times each in X, Y, and Z directions						
Degree of protection		IP67 (IEC 60529)						
Connection method		Pre-wired (standard lengths: 2 m and 0.5 m)	Connector (M8, 4 pins)	Pre-wired (standard lengths: 2 m and 0.5 m)	Connector (M8, 4 pins)			
Indicators		Operation indicator (orange), Stability indicator (green)						
Weight (packed state)		Pre-wired Sensors, 2 m: Approx. 65 g	Approx. 20 g	Pre-wired Sensors, 2 m: Approx. 65 g	Approx. 20 g			
Motorial	Case	PBT (polybutylene terephthalate)						
Material	Lens	Modified polyarylate resin						
Accessories	3	Instruction manual (Mounti	ng Brackets must be ordered	d separately.)				

2


### **Engineering Data**

### **Operating Range**


### E3Z-LS 1/LS 6 **BGS**



### **FGS**




### E3Z-LS 3/LS 8




### **Spot Diameter vs. Sensing Distance**

### E3Z-LS 1/LS 6




E3Z-LS 3/LS 8



### **Close-range Characteristics**

### E3Z-LS 1/LS 6


**OMRON** 



E3Z-LS


3/LS

8




### **Differential Travel vs. Sensing Distance**

### E3Z-LS 1/LS 6




### E3Z-LS 3/LS 8




### **Sensing Object Angle Characteristics**

### E3Z-LS 1/LS 6

### Vertical




### Horizontal




### E3Z-LS 3/LS 8

### Vertical




### Horizontal




### **FGS Mode Set Distance**

### E3Z-LS□1/LS□6 White Paper




### **Black Paper**




### Sensing Distance vs. Sensing Object Material

E3Z-LS 1/LS 6


### Set Distance of 40 mm using White Paper




Set Distance of 200 mm using White Paper




E3Z-LS□3/LS□8
Set Distance of 20 mm using White Paper



Set Distance of 80 mm using White Paper



### I/O Circuit Diagrams



Note: The VERY FAR region is supported only for FGS.
The incident light level threshold is fixed and cannot be set.


### **NPN Output**

Model	Operation mode	Timing charts	Operation selector	BGS/FGS selection method	Output circuit		
E3Z-LS61 E3Z-LS66 E3Z-LS63 E3Z-LS68	Light-ON	Operation indicator (orange) OFF Output transistor ON OFF Load ON (e.g., relay) OFF (Between brown and black leads)	L side (LIGHT ON)	BGS: Either leave the pink wire (2) open or connect it to the blue wire (3).	Province 42 to 24 VDC		
	Dark-ON	Operation indicator (orange) OFF Output transistor OFF Load ON (e.g., relay) OFF (Between brown and black leads)	D side (DARK ON)		Stability indicator (green)  Operation indicator (orange)  Operation indicator (corange)  Pink  FGS  Load (relay)  100 mA  Main Circuit  Zo  Blue  Bigs  Others  Bigg  Bigg  Others  Bigg  Bigg  Others  Bigg  B		
E3Z-LS61 E3Z-LS66	Light-ON	Operation indicator (orange) OFF ON transistor Load ON (e.g., relay) OFF (Between brown and black leads)	L side (LIGHT ON)	FGS: Connect the pink wire (2) to the brown wire (1).	FGS: Connect the pink wire (2) to the brown wire (1).	_ side LIGHT ON) FGS: Connect Arrangement	
	Dark-ON	Operation indicator (orange) OFF OFF Load ON (e.g., relay) OFF (Between brown and black leads)	D side (DARK ON)			4 (-)	


### **PNP Output**

Model	Operation mode	Timing charts	Operation selector	BGS/FGS selection method	Output circuit
E3Z-LS81 E3Z-LS86 E3Z-LS83 E3Z-LS88	Light-ON	Operation indicator (orange) OFF OUtput transistor OFF Load (e.g., relay) OFF (Between blue and black leads)	L side (LIGHT ON)	BGS: Either leave the pink wire (2)	
	Dark-ON	Operation ON indicator (orange) OFF Output ON transistor OFF OLgad ON (e.g., relay) OFF (Between blue and black leads)	D side (DARK ON)	open or connectitto the blue wire (3).	Operation indicator (green)  Photo-electric electric (Control output)  Sensor Main Circuit  Pink  Load (relay)  Brown 12 to 24 VDC  FGS  Black  Photo-electric (Control output)  Pink  Load (relay)
E3Z-LS81 E3Z-LS86	Light-ON	Operation indicator (orange) OFF OFF OFF (Between blue and black leads)	L side (LIGHT ON)	FGS: Connect the pink	Connector Pin Arrangement  (2) (3) (3)
	Dark-ON	Operation indicator (orange) Output transistor Ce.g., relay) OFF (Between blue and black leads)	D side (DARK ON)	wire (2) to the brown wire (1).	

### Plugs (Sensor I/O Connectors)



### **Nomenclature**



OMRON

### **Safety Precautions**

### Refer to Safety Precautions of the E3Z and Warranty and Limitations of Liability.

### **WARNING**

This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.



## Caution

Do not connect an AC power supply to the Sensor. If AC power (100 VAC or more) is supplied to the Sensor, it may explode or burn.



### **Precautions for Safe Use**

Be sure to abide by the following precautions for the safe operation of the Sensor.

### Wiring

### **Power Supply Voltage and Output Load Power Supply** Voltage

Make sure that the power supply to the Sensor is within the rated voltage range. If a voltage exceeding the rated voltage range is supplied to the Sensor, it may explode or burn.

### Load Short-circuiting

Do not short-circuit the load, otherwise the Sensor may be damaged.

### **Connection without Load**

Do not connect the power supply to the Sensor with no load connected, otherwise the internal elements may explode or burn.

### Operating Environment

Do not use the Sensor in locations with explosive or flammable gas.

### **Precautions for Correct Use**

Do not use the product in atmospheres or environments that exceed product ratings.

### Designing

### **Power Reset Time**

The Sensor is ready to operate 100 ms after the Sensor is turned ON. If the load and Sensor are connected to independent power supplies respectively, be sure to turn ON the Sensor before supplying power to the load.

### Wiring

### **Avoiding Malfunctions**

If using the Sensor with an inverter or servomotor, always ground the FG (frame ground) and G (ground) terminals, otherwise the Sensor may malfunction.

### Mounting

### **Mounting the Sensor**

- If Sensors are mounted face-to-face, make sure that the optical axes are not in opposition to each other. Otherwise, mutual interference may result.
- Always install the Sensor carefully so that the aperture angle range of the Sensor will not cause it to be directly exposed to intensive light, such as sunlight, fluorescent light, or incandescent light.
- Do not strike the Photoelectric Sensor with a hammer or any other tool during the installation of the Sensor, or the Sensor will lose its water-resistive properties.
- Use M3 screws to mount the Sensor.
- When mounting the case, make sure that the tightening torque applied to each screw does not exceed 0.54 N·m.

### **M8 Connector**


- Always turn OFF the power supply to the Sensor before connecting or disconnecting the metal connector.
- Hold the connector cover to connect or disconnect it. If the XS3F is used, always tighten the connector cover by hand. Do not use pliers.

If the connector is not connected securely, it may be disconnected by vibration or the proper degree of protection of the Sensor may not be maintained. The appropriate tightening torque is 0.3 to 0.4

If other commercially available connectors are used, follow the recommended connector application conditions and recommended tightening torque specifications.

### **Mounting Directions**

• Make sure that the sensing side of the Sensor is parallel with the surface of the sensing objects. Normally, do not incline the Sensor towards the sensing object.




Glossy object


If the sensing object has a glossy surface, however, incline the Sensor by  $5^{\circ}$  to  $10^{\circ}$  as shown in the illustration, provided that the Sensor is not influenced by background objects.

• If there is a mirror-like object below the Sensor, the Sensor may not operate stably. Therefore, incline


the Sensor or separate the Sensor from the mirror-like object as shown below.



• Do not install the Sensor in the wrong direction. Refer to the following illustration.




Install the Sensor as shown in the following illustration if each sensing object greatly differs in color or material.



### Adjusting

### **Indicator Operation**



Note: 1. If the stability indicator is lit, the detection/no detection status is stable within the rated ambient operating temperature (–25 to 55°C).


The VERY FAR region is supported only for FGS. The incident light threshold is fixed and cannot be set. The distance to the incident light threshold depends on the color and gloss of the sensing object's surface.


### • Inspection and Maintenance

### Cleaning

Never use paint thinners or other organic solvents to clean the surface of the product.

## (Unit: mm) Tolerance class IT16 applies to dimensions in this datasheet unless otherwise specified.





### **Read and Understand This Catalog**

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

### Warranty and Limitations of Liability

### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

### **Application Considerations**

### SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

### PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

### **Disclaimers**

### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

### **DIMENSIONS AND WEIGHTS**

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2008.11

In the interest of product improvement, specifications are subject to change without notice.





Компания «Океан Электроники» предлагает заключение долгосрочных отношений при поставках импортных электронных компонентов на взаимовыгодных условиях!

### Наши преимущества:

- Поставка оригинальных импортных электронных компонентов напрямую с производств Америки, Европы и Азии, а так же с крупнейших складов мира;
- Широкая линейка поставок активных и пассивных импортных электронных компонентов (более 30 млн. наименований);
- Поставка сложных, дефицитных, либо снятых с производства позиций;
- Оперативные сроки поставки под заказ (от 5 рабочих дней);
- Экспресс доставка в любую точку России;
- Помощь Конструкторского Отдела и консультации квалифицированных инженеров;
- Техническая поддержка проекта, помощь в подборе аналогов, поставка прототипов;
- Поставка электронных компонентов под контролем ВП;
- Система менеджмента качества сертифицирована по Международному стандарту ISO 9001;
- При необходимости вся продукция военного и аэрокосмического назначения проходит испытания и сертификацию в лаборатории (по согласованию с заказчиком);
- Поставка специализированных компонентов военного и аэрокосмического уровня качества (Xilinx, Altera, Analog Devices, Intersil, Interpoint, Microsemi, Actel, Aeroflex, Peregrine, VPT, Syfer, Eurofarad, Texas Instruments, MS Kennedy, Miteq, Cobham, E2V, MA-COM, Hittite, Mini-Circuits, General Dynamics и др.);

Компания «Океан Электроники» является официальным дистрибьютором и эксклюзивным представителем в России одного из крупнейших производителей разъемов военного и аэрокосмического назначения «JONHON», а так же официальным дистрибьютором и эксклюзивным представителем в России производителя высокотехнологичных и надежных решений для передачи СВЧ сигналов «FORSTAR».



**«JONHON»** (основан в 1970 г.)

Разъемы специального, военного и аэрокосмического назначения:

(Применяются в военной, авиационной, аэрокосмической, морской, железнодорожной, горно- и нефтедобывающей отраслях промышленности)

«**FORSTAR**» (основан в 1998 г.)

ВЧ соединители, коаксиальные кабели, кабельные сборки и микроволновые компоненты:

(Применяются в телекоммуникациях гражданского и специального назначения, в средствах связи, РЛС, а так же военной, авиационной и аэрокосмической отраслях промышленности).



Телефон: 8 (812) 309-75-97 (многоканальный)

Факс: 8 (812) 320-03-32

Электронная почта: ocean@oceanchips.ru

Web: http://oceanchips.ru/

Адрес: 198099, г. Санкт-Петербург, ул. Калинина, д. 2, корп. 4, лит. А